


NOTICE IN INSTALLING VALVE. (2)

HIGH PRESSURE
SIDE IN VALVE
SHUT POSITION



LOW PRESSURE
SIDE IN VALVE
SHUT POSITION

DIMENSIONS										UNIT : mm					
NOMINAL SIZE		d	H	D1	L	END FLANGE									
						D	BOLT HOLE			BOLT SIZE	g	t	f		
in.	mm	C	NO.	h											
1/2	15	15	102	130	140	95	66.5	4	16	1/2	35	14.3	1.6		
3/4	20	20	105	130	152	117	82.5	4	19	5/8	43	15.9	1.6		
1	25	25	124	160	165	124	89.0	4	19	5/8	51	17.6	1.6		
1.1/2	40	40	136	600	190	156	114.5	4	22	3/4	73	20.7	1.6		
2	50	50	141	600	216	165	127.0	8	19	5/8	92	22.3	1.6		
2.1/2	65	65	187	1000	241	190	149.0	8	22	3/4	105	25.4	1.6		
3	80	80	197	1000	283	210	168.0	8	22	3/4	127	28.6	1.6		

NOTE (1) VALVE SIZE (inch) IDENTIFICATION.
(2) PLEASE INSTALL VALVE SO THAT THE ARROW INDICATED SHOULD BE IN THE ABOVE DIRECTION.
(3) ALLOWABLE SEAT LEAKAGE SHALL BE IN ACCORDANCE WITH ANSI/FCI 70-2 CLASS VI.